



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2011010305459786

**NAME AND ADDRESS OF THE APPLICANT**

Steute Technologies GmbH & Co. KG  
Brueckenstrasse 91, 32584 Loehne, Germany

**NAME AND ADDRESS OF THE MANUFACTURER**

Steute Technologies GmbH & Co. KG  
Brueckenstrasse 91, 32584 Loehne, Germany

**NAME AND ADDRESS OF THE FACTORY**

Steute Technologies GmbH & Co. KG (V040639)  
Brueckenstrasse 91, 32584 Loehne, Germany

**PRODUCT NAME, MODEL AND SPECIFICATION**

Position Switch

EM14, E12, Ex14, Ex12:

Ui:250V;Uimp:4kV;AC-15:Ue/Ie:AC250V/5A;DC-13:Ue/Ie:DC230V/0.16A;lth:5A;IP67; models explain see attached

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.5-2017

**TYPE OF CERTIFICATION SCHEMES**

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Feb.20,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

**President:** \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0182200



# 产品认证证书

证书编号: CQC2011010305459786

申请人名称及地址

Steute Technologies GmbH & Co. KG  
Brueckenstrasse 91, 32584 Loehne, Germany

制造商名称及地址

Steute Technologies GmbH & Co. KG  
Brueckenstrasse 91, 32584 Loehne, Germany

生产企业名称及地址

Steute Technologies GmbH & Co. KG (V040639)  
Brueckenstrasse 91, 32584 Loehne, Germany

产品名称和系列、规格、型号

位置开关

EM14, E12, Ex14, Ex12:

Ui:250V;Uimp:4kV;AC-15:Ue/Ie:AC250V/5A;DC-13:Ue/Ie:DC230V/0.16A;Ith:5A;IP67; 型号详见附件

产品标准和技术要求

GB/T14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020年02月20日

本证书的有效性依据发证机构的定期监督获得保持。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0182200